

Office of The Chief Medical Officer, Ghaziabad

Ref.No: DSO/IDSP/2022/ 836

Dated 12-11-2022

Safe Drinking Water, Health & Hygiene Certificate

It is certified that a combined inspection team headed by Mr. Sujit Kumar Rai from IDSP UNIT, Ghaziabad and Nagar Nigam, Ghaziabad inspected the premises DELHI PUBLIC SCHOOL GHAZIABAD VASUNDHARA on 10-11-2022 and found DELHI PUBLIC SCHOOL GHAZIABAD VASUNDHARA has safe Drinking water facilities for the person is maintaining hygienic sanitation conditions in the water as per the norms. This certificate is issued with the condition that the water quality will be maintained in future otherwise, it will automatically stand canceled on proof.

Based on Ref: DSO/IDSP/2022/ 836

(Dr. R K Gupta)

District Public Health Expert

District Surveillance Officer
Ghaziabad
District Public Health Expert
District Ghaziabad

To

DELHI PUBLIC SCHOOL GHAZIABAD VASUNDHARA

Office of The Chief Medical Officer, Ghaziabad

Ref.No. DSO/IDSP/2022/ 336

Dated 12/11/2022

PORTABLE WATER TEST REPORT

Address:- DELHI PUBLIC SCHOOL GHAZIABAD VASUNDHARA

No of sample collected : 01

Date of sample collected : 10-11-2022

Sample collection area

Sample collection area	Sample ID	Result
DELHI PUBLIC SCHOOL GHAZIABAD VASUNDHARA	701	Satisfactory

Test Result

H₂S Water test kit : Negative (-Ve) after 24-48 hrs incubation

Comments:-

H₂S water test kit report - ve reflects that water is free from Coliforms Organism.

Recommendation:

Given water sample safe for drinking purpose.

Lab Technician
IDSP Lab
Ghaziabad

Suruchi Saini
(Dr. Suruchi Saini)
Microbiologist IDSP Lab
Ghaziabad

R.K. Gupta
(Dr R.K Gupta)
District Public Health Expert
Ghaziabad
District Surveillance Officer
District Public Health Expert
District Ghaziabad